



3/8" CRUSHED AGGREGATE GRADING RESULTS

PROJECT

LOCATION

CUSTOMER

TRACK #

Sieve Size	Wt. Ret.	% Ret.	% Passing	Lower Limit	Upper Limit
1/2" (12.5mm)	0	0	100	100	100
3/8" (9.5mm)	11	1	99	90	100
#4 (4.75mm)	1035	68	32	30	60
#8 (2.36mm)	1468	96	4	0	10
Pan	1533				

Grading Limits Are In Accordance With Sec. 200-1.2 Of The Public Works "Green Book"

