



# BIRDS EYE GRADING RESULTS

PROJECT .....

LOCATION .....

CUSTOMER .....

TRACK # .....

Sieve Size	Wt. Ret.	% Ret.	% Passing	Lower Limit	Upper Limit
3/4" (19.0mm)	0	0	100	100	100
3/8" (9.5mm)	0	0	100	85	100
#4 (4.75mm)	134	27	73	0	30
#8 (2.36mm)	383	77	23	0	10
#200 (75um)	489	98	2	0	2
Pan	497				

Grading Limits Are In Accordance With Sec. 200 Of The Public Works "Green Book"

