



ROCK DUST GRADING RESULTS

PROJECT

LOCATION

CUSTOMER

TRACK #

Sieve Size	Wt. Ret.	% Ret.	% Passing	Lower Limit	Upper Limit
3/8" (9.5mm)	0	0	100	100	100
#4 (4.75mm)	17	3	97	90	100
#30 (600um)	307	60	40	20	60
#200 (75um)	455	89	11	5	20
Pan	514				

Grading Limits Are In Accordance With Sec. 200-1.2 Of The Public Works "Green Book"

