



SE 20 FILL SAND GRADING RESULTS

PROJECT

LOCATION

CUSTOMER

TRACK #

Sieve Size	Wt. Ret.	% Ret.	% Passing
#4 (4.75mm)	87	15	85
#8 (2.36mm)	276	48	52
#16 (1.18mm)	368	64	36
#30 (600um)	408	70	30
#50 (300um)	441	76	24
#100 (150um)	488	84	16
#200 (75um)	547	94	6
Pan	579	S.E. 27	

