



SE 30 FILL SAND GRADING RESULTS

PROJECT

LOCATION

CUSTOMER

TRACK #

Sieve Size	Wt. Ret.	% Ret.	% Passing
#4 (4.75mm)	39	8	92
#8 (2.36mm)	93	18	82
#16 (1.18mm)	154	30	70
#30 (600um)	235	45	55
#50 (300um)	342	66	34
#100 (150um)	413	80	20
#200 (75um)	443	85	15
Pan	519	S.E. 35	

