



TYPE 1 AGGREGATE SLURRY GRADING RESULTS

PROJECT

LOCATION

CUSTOMER

TRACK #

Sieve Size	Wt. Ret.	% Ret.	% Passing	Green Book Spec.		Caltrans Spec.	
				Lower Limit	Upper Limit	Lower Limit	Upper Limit
#4 (4.75mm)	0	0	100	100	100	100	100
#8 (2.36mm)	3	1	99	90	100	90	100
#16 (1.18mm)	89	18	82	65	90	60	90
#30 (600um)	214	44	56	40	60	40	65
#50 (300um)	310	64	36	25	42	-	-
#100 (150um)	375	77	23	15	30	-	-
#200 (75um)	415	86	14	10	20	10	20
Pan	484			S.E. 62			

