



WASHED CONCRETE SAND GRADING RESULTS

PROJECT

LOCATION

CUSTOMER

TRACK #

Sieve Size	Wt. Ret.	% Ret.	% Passing	Lower Limit	Upper Limit
3/8" (9.5mm)	0	0	100	100	100
#4 (4.75mm)	20	5	95	95	100
#8 (2.36mm)	68	18	82	75	90
#16 (1.18mm)	147	39	61	55	75
#30 (600um)	259	64	36	30	50
#50 (300um)	378	88	12	10	25
#100 (150um)	439	96	4	2	10
#200 (75um)	456	99	1	0	5
Pan	461	S.E. 92			

Grading Limits Are In Accordance With Sec. 200-1.5.4 Of The Public Works "Green Book"

