



WASHED PLASTER SAND GRADING RESULTS

PROJECT

LOCATION

CUSTOMER

TRACK #

| Sieve Size | Wt. Ret. | % Ret. | % Passing | Lower Limit | Upper Limit |
|--------------|----------|---------|-----------|-------------|-------------|
| #4 (4.75mm) | 0 | 0 | 100 | 100 | 100 |
| #8 (2.36mm) | 5 | 1.1 | 99 | 95 | 100 |
| #16 (1.18mm) | 61 | 14 | 86 | 70 | 95 |
| #30 (600um) | 174 | 39 | 61 | 35 | 70 |
| #50 (300um) | 312 | 69 | 31 | 5 | 35 |
| #100 (150um) | 411 | 91 | 9 | 0 | 10 |
| #200 (75um) | 444 | 99 | 1 | 0 | 5 |
| Pan | 450 | S.E. 85 | | | |

Grading Limits Are In Accordance With Sec. 200-1.5.4 Of The Public Works "Green Book"

